

Las Vegas Fire and Rescue is dedicated to providing “Fire and Life Safety inspections, Plan Review, and Public Education services to the citizens and customers of the city of Las Vegas”.

Contact Information:

Las Vegas Fire & Rescue

Fire Prevention Division

500 N Casino Center Blvd. LV NV 89101

Phone: 702-229-0366

Fax: 702-229-0124

Website: <http://www.lasvegasnevada.gov/Government/fire.htm>

Office Hours:

6 a.m. to 5 p.m. Monday thru Friday

(With exception to holidays)

Inspections:

Business License Inspection Information

Fire Prevention conducts license inspections within 10 working days of being received. Fire Prevention will attempt to contact the owner/operator listed on the license application to schedule a fire life safety inspection. If you have a special situation or have questions about your particular business, please contact the Fire Prevention office.

NOTE: If the business is not ready to open, is still under construction, requires a new Certificate of Occupancy for change or use, conducted unpermitted improvements, has an incorrect address or we are not able to contact the owner/operator, the business license may be denied until the appropriate items have been completed or corrected.

General Code Requirements:

NOTE: The following are examples of general items that shall be in compliance. Specific occupancy types or operations may have specific requirements.

Addressing – Your business address shall be installed in accordance with the city of Las Vegas addressing ordinance number 6052, (including suite number if applicable).

Building or Tenant Space -

- There shall be no holes or breaches in the ceiling or walls.
- The main entrance exit must be able to be operated from the inside with no special knowledge or effort. This door shall have a sign on interior side of the door that reads:
“THIS DOOR SHALL REMAIN UNLOCKED DURING BUSINESS HOURS”
- Any required exiting shall remain clear of any obstructions
- Emergency lights and illuminated exit signs shall be provided for all required exiting.
The business or occupancy type shall have an appropriate Certificate of Occupancy. (This is required to assure that the business operation is compatible within the space or building.
- At least one fire extinguisher with a minimum size of 2-A: 10 BC shall be provided for every business.
The extinguisher shall be tagged by a State of Nevada contractor. (Do not go to your local hardware

store and purchase one, it will still have to be tagged). *Some businesses or operations will require a specialized extinguisher. (Contact Fire Prevention for such requirements).

The fire extinguisher shall be mounted on the wall in the path of egress (near the front door) and no higher than 5 feet from the floor.

Storage – General storage shall not be placed into any egress or exit stair. General storage shall be limited to 12 feet in height kept a minimum of 24” from the ceiling in a non-sprinklered building. In a Sprinklered building it shall be a minimum of 18” below the sprinkler head. Storage shall not be allowed in any hazardous areas such as boiler rooms, mechanical rooms, Fire Sprinkler Riser rooms, electrical rooms or any other similar type rooms.

Fire Alarm / Fire Sprinkler Systems / Kitchen Hood Extinguishing Systems – Any such systems and associated devices (sprinkler heads, smoke detectors, fire alarm devices, etc.) shall be tested, maintained and tagged by a State of Nevada licensed contractor. (Fire inspection staff will ask for proof of such).

Place of Assembly / Special Occupancies – Locations having an established occupant load of more than 49 persons will be classified as a place of assembly and an operational permit is required.

New Construction Inspection Requests:

Inspection requests for the following work day will be accepted up to 7 p.m. on the previous day. On the scheduled day of the inspection, assigned Fire Prevention staff will contact you to coordinate your inspection time.

Example: *Inspection request on Monday at 5 p.m. will schedule your inspection on Tuesday*

To schedule a new construction inspection you can use our Interactive Voice Response (IVR) system at 702-229-4677 or access our website <http://www.lasvegasnevada.gov/Schedule/inspections.htm>

Please have the Have the following information ready when attempting to schedule your inspection.

- Permit (AP) number
- Street address number
- Inspection type

PIN number. If you do not have a PIN number call 702-229-4722 and staff will assist you in obtaining the number.